


FOR CONNECTION TO WATER SYSTEM WITH NO ELECTRIC START/STOP (SUCH AS CITY WATER SUPPLY):

COMPLETE SYSTEM PART No. 11-ABS-001, INCLUDES:

- (1) NOZZLE ASSEMBLY (SELECT SIZE)
- (20') POLY TUBE, 1/4"
- (1) CONTROL BOX, WITH PRESSURE SWITCH, RELAY AND START/STOP PUSHBUTTONS.
- (2) HOSE CLAMPS
- (6) CABLE TIES

OPTIONAL EQUIPMENT:


- (1) SOLENOID VALVE, 120VAC (SELECT SIZE)
NOTE: SOLENOID VALVE REQUIRED FOR PROPER OPERATION.
- WATER HOSE (SELECT SIZE), LENGTH AS NEEDED.



IMPORTANT INSTALLATION NOTES:

- *MOUNT CONTROL BOX AS CLOSE AS POSSIBLE TO THE WATER FILL HOSE/NOZZLE ASSEMBLY TO KEEP THE POLY HOSE SHORT.
- *ASSEMBLE WATER FILL HOSE/NOZZLE ASSEMBLY SO IT WILL DRAIN WHEN NOT IN USE - SO THAT IT HANGS STRAIGHT DOWN AS SHOWN.
- *AFTER INSTALLATION IS COMPLETE, INSERT FILL NOZZLE INTO WATER TANK UNTIL IT HITS THE STOP, TURN ON WATER. IT WILL SHUT OFF AUTOMATICALLY.
- *GROUND PER NATIONAL AND LOCAL CODES.

A		UPDATE	FOX	07SEP07	THIS DRAWING IS CONFIDENTIAL PROPERTY OF BFK TECHNOLOGIES INC. THIS DRAWING AND ITS CONTENTS MAY NOT BE REPRODUCED, PUBLISHED OR DISCLOSED TO ANYONE WITHOUT PRIOR CONSENT OF BFK TECHNOLOGIES INC.
REV	ECD	DESCRIPTION	BY	DATE	

SCALE NONE	 Jamieson Equipment Company toll free 800.875.0280 sales@jamiesonequipment.com www.jamiesonequipment.com
DRAWN BY FOX	
DATE 10 JULY 02	TITLE INSTALLATION, MODEL B WATERDOG CONTROL VALVE NO EXISTING ELECTRIC CONTROLS
ENGINEER	DRAWING NUMBER
DATE	11-AOF-001
APPROVED BY	REV A
DATE	